

## Multiple-sector interface in housing

---



### Part-No. 788023.10

Approval: VdS

For the formation of multiple-sector control, up to four extinguishing panels 8010 can be networked via a multiple-sector interfaces. The cascading of a max. of 3 multiple-sector interface is possible for multi-sector control of a max. of 10 extinguishing panels 8010.