

CO test gas for smoke detector tester 805582



Part-No. 805583

Test gas for testing carbon monoxide CO-detectors. Specifically designed for the OTG multisensor fire detector (CO) IQ8Quad with isolator (Part No. 802473), suitable for smoke detector tester Part No. 805582.

Air humidity	< 95 %
--------------	--------



The OTG multisensor fire detector (CO) IQ8Quad with isolator (Part No. 802473) should only be tested in connection with test gas Part No. 060430.10 suitable for smoke detector tester Part No. 805582. Detector Part No. 802473 has been approved as smoke detector by VdS and the CO test gas is used to additionally trigger the electrochemical CO-gas cell. Please see our website for latest edition of the safety data sheet.

Due to its nature, this article can pose hazards to man and the environment. Please clarify in advance with your forwarding agent if he accepts the transport of dangerous goods and if necessary observe the import regulations. The dangerous goods class for road transport or air transport is as follows:

UN-No. UN1950
ADR-Class 2